

This item was submitted to Loughborough's Research Repository by the author. Items in Figshare are protected by copyright, with all rights reserved, unless otherwise indicated.

Optimisation of sewage treatment process at Pagla

PLEASE CITE THE PUBLISHED VERSION

PUBLISHER

© WEDC, Loughborough University

VERSION

VoR (Version of Record)

PUBLISHER STATEMENT

This work is made available according to the conditions of the Creative Commons Attribution-NonCommercial-NoDerivatives 4.0 International (CC BY-NC-ND 4.0) licence. Full details of this licence are available at: https://creativecommons.org/licenses/by-nc-nd/4.0/

LICENCE

CC BY-NC-ND 4.0

REPOSITORY RECORD

Amin, A.F.M. Saiful, Sk Abu Jafar Shamsuddin, and Md. Monirul Alam. 2019. "Optimisation of Sewage Treatment Process at Pagla". figshare. https://hdl.handle.net/2134/28548.



24th WEDC Conference

SANITATION AND WATER FOR ALL

Optimisation of sewage treatment process at Pagla

A.F.M. Saiful Amin, S.A.J. Shamsuddin and M.M. Alam, Bangladesh



THE SEWAGE TREATMENT plant of the Dhaka Metropolitan, known as Pagla Sewage Treatment Plant (PSTP) was designed to treat a maximum flow of 120,000 m³/day of domestic sewage generated from about 18 per cent population of the metropolitan. The final effluent from the treatment plant is discharged into the adjacent Buriganga River. The treatment process in application is basically a low cost option consisting of grit chamber, primary sedimentation tank, facultative lagoon, chlorination system and sludge lagoon (Figure 1). There has always been a general complaint of shortcomings of the overall performance of the plant, which is in fact evident from an obnoxious and foul smell even at the fag end of the plant.

In quest of optimisation of treatment process; a study was undertaken where both qualitative and quantitative aspects of sewage with particular emphasis on the characteristics of influent, effluent and sludge were checked and determined with laboratory aids. The hourly as well as seasonal variations of various parameters were also stud-

Table 1. Design criteria of the existing plant			
Grit Chamber			
Surface loading rate	3600m ³ /m ² /d		
Detention time	60 sec.		
Average velocity	0.30 m/sec.		
Primary Sedimentation Tank			
Surface loading rate	$35m^3/m^2/d$		
Detention time	2.0 hours		
Weir loading rate	$3600 m^3/m/d$		
Facultative Lagoon			
Influent BOD concentration	120ppm		
Ambient temperature	21°C		
Pond depth	2.0m		
Detention time	7 days		
Chlorination			
Chlorine dosage rate	3.0ppm		
Sludge Lagoon			
Lagoon volume rate	50kg/year/m ³		
Digesting time	Over the 90 days		
Content of volatile solids	60%		
Reduction rate of volatile solids	35%		
Moisture rate of dried sludge	80%		

ied. This paper highlights some significant aspects of the study and aims at drawing conclusions in order to facilitate optimising the sewage treatment operation of the plant.

Salient features of the existing plant

Table 1 and Table 2 present the salient features entailing design criteria and designed wastewater quality of the existing treatment plant (NJSCL 1987).

Characterization of influent, effluent and sludge

Different parameters like flow rate, pH, dissolved oxygen content, biochemical oxygen demand, chemical oxygen demand, suspended solids, total nitrogen, total phosphorus, chloride and faecal coliform count were determined for the samples collected six times a day for the influent and three times a day for the final effluent of both wet season (June 1997) and dry season (December 1997). The heavy metal concentrations in the sludge from the treatment plant and in the septic tanks of individual households as well were determined. All these laboratory determinations were carried out following standard methods (APHA 1989 and AWWA 1985).

Findings from the study

Flow rate

In the present study, the average flow rate at the inlet was estimated as 163,000 m^3/day in wet season. However, in the dry season the rate dropped at 122,250 m^3/day , which was even higher than that of the designed maximum flow rate. At the outlet point of the plant, the flow in the wet season was estimated as 38,163 m^3/day while that in the dry season was 31,780 m^3/day .

Influent characteristics

- The pH was found to be almost neutral during the dry season. However, in the wet season, it was recorded to be a little bit basic.
- The dissolved oxygen content was found to be higher in the dry season (0.41-1.2 ppm) than that of the wet season (0.20-0.52 ppm).
- The BOD₅ values at 20°C and COD values were found to be excessive (of the range of 500 ppm to 2500 ppm) in both the seasons, which are very unusual in domestic sewage.

- The concentration of the suspended solid particles was also detected to be on the higher side (Max. 960 ppm) than the normal domestic sewage.
- The total nitrogen (T-N), total phosphorus (T-P) and chloride (Cl) loadings were found to be consistent throughout the whole day. However, the T-P and Cl loadings were distinctly found to be low in the wet season than that of dry season.
- The faecal coliform count was very high in both the seasons with the highest values during night-time (3.0×10^{5} - 2.9×10^{6} n/100ml).

Effluent characteristics

- The pH of the effluent was found to be on the basic range (7.6 – 8.8) in both seasons. A higher value was observed in the wet season.
- The dissolved oxygen content was found to be higher in the winter (1.01-2.27 ppm), but very low (0.42-1.2 ppm) in the other season.
- The BOD₅ values (at 20°C) and COD values throughout the whole day of the rainy season were found to be very high (Max. 455 and 475 ppm respectively) and exceed the limits of Bangladesh Environmental Quality Standard (GOB 1997) for discharge into a surface water

- body. This situation was found to be worse in the winter (Max. 720 and Max. 830 ppm respectively).
- The suspended solids concentration at noon-afternoon was found to be the highest (Max. 180 ppm) and also to exceed the limits of Bangladesh Environmental Quality Standard (GOB 1997) for discharge into a surface water body.
- The T-N, T-P and chloride concentrations were found to be higher in the winter.
- The faecal coliform count was found to be excessively high ($3 \times 10^{4} \cdot 2.5 \times 10^{5} \text{ n/100 ml}$) exceeding the limit of Bangladesh Environmental Quality Standards (GOB 1997).

Sludge bed

The concentrations of heavy metals in the sludge bed, particularly lead, chromium, copper, zinc and nickel were found excessively high in comparison to sludges of domestic septic tanks of different communities of the Dhaka City.

Table 3 presents a comparative picture of heavy metals' concentration of the sludges of the treatment plant and domestic septic tanks.

Table 2. Designed Wastewater Quality of the Treatment Plant						
Parameter	Influent sewage quality (ppm)	Primary tank removal rate (%)	Sedimentation effluent water quality (ppm)	Facultative lagoon removal rate (%)	Effluent water quality (ppm)	Total removal rate (%)
BOD ₅	200	40	120	59	50	75
Suspended solids	200	60	80	25	60	70

Heavy Metals	Concentration (ppm)		
	Sludge bed of PSTP	Domestic septic tanks	
Cadmium	0.15	<0.01 - 0.015	
Mercury	0.23	0.01 - 0.03	
Arsenic	0.40	< 0.05 - 0.06	
Lead	28.70	< 0.01	
Chromium	66.66	<0.01 - 0.03	
Copper	461.88	0.75 - 1.75	
Zinc	1193	0.025 - 0.050	
Nickel	23.00	0.01 – 0.03	

	nt T
	Figure 1. General flow of pagla sewage treatment plant
	vage trea
	pagla sev
	I flow of I
	L. Genera
	Figure 1

Conclusion

The following conclusions are drawn from the study:

- The wastewater quality of the final effluent of the treatment plant exceeds the allowable limits of environmental quality standards for discharge into a surface water body.
- The abnormally high figures of BOD, COD, TDS and a very low level of DO content indicate the presence of pollutants having origins other than usual domestic sewage.
- Presence of heavy metals at objectionable levels particularly in the sludge bed, indicates contaminations from industrial pollutants particularly from tanneries, textiles, zinc & nickel plating and other chemical industries that are located within and outskirts of the city (Rahman 1997).
- Decomposed sludge materials are not suitable for use directly as fertiliser or in land filling operation.

Recommendations

A rapid assessment is required to be made in regard to the locations and settings of dispersed as well as cluster of industries, qualitative and quantitative nature of industrial effluent and disposal methods of industrial wastes.

As a long-term strategy, upon completion of rapid assessment, industrial effluents are to be prevented from entering into the domestic sewer network of the PSTP. Industries are to be responsible for treating their wastes.

As short term and interim measures the surface loading at the grit chamber is required to be reduced and the retention period in the primary sedimentation tank should be increased. Dosage of disinfectant is to be monitored and applied accordingly prior to discharging the final effluent into the Buriganga River.

References

NIPPON JOGESUIDO SEKKEI CO. LTD., JAPAN (NJSCL), 1987, Urgent Sewerage Construction and Rehabilitation for Dhaka City - Project Summary.

AMERICAN PUBLIC HEALTH ASSOCIATION (APHA), 1989, Standard Methods for the Examination of Water and Wastewater, 17th edition.

AMERICAN WATER WORKS ASSOCIATION (AWWA), 1985, Standard Methods for the Examination of Water and Wastewater, 16th edition.

GOVERNMENT OF THE PEOPLES' REPUBLIC OF BANGLADESH (GOB), 1997, Environment Conservation Act, Bangladesh Gazette.

RAHMAN, M. A., 1997, Characteristics of Major Industrial Liquid Pollutants in Bangladesh, M.Engg. Thesis, Bangladesh University of Engineering and Technology.

A.F.M. SAIFUL AMIN, Department of Civil Engineering, Bangladesh University of Engineering and Technology, Dhaka 1000, Bangladesh.

S.A.J. SHAMSUDDIN, Rural Specialist, RWSG-SA, Bangladesh Country Team, World Bank, Dhaka, Bangladesh. M.M. ALAM, Department of Geography and Environment, Dhaka University, Dhaka 1000, Bangladesh.

Figure 2. Variation of pH in the influent and final effluent